

# Queen's University - Air Exchange Review

Teaching Spaces

February 2022 Update

<i>Building Name</i>	<i>Room Code</i>	<i>eACH</i>	<i>Source</i>	<i>HEPA Filter(s)</i>
Abramsky Hall	007	11.9	Calculated	No
Beamish-Munro Hall	108	> 6 *	Modern	No
Beamish-Munro Hall	108A	> 6 *	Modern	No
Beamish-Munro Hall	109	> 6 *	Modern	No
Beamish-Munro Hall	110	> 6 *	Modern	No
Beamish-Munro Hall	111	9.7	Calculated	No
Beamish-Munro Hall	212	8.0	Measured	No
Beamish-Munro Hall	213	7.4	Measured	No
Beamish-Munro Hall	214	5.6	Measured	No
Beamish-Munro Hall	313	7.3	Measured	No
Beamish-Munro Hall	314	5.1	Measured	No
Beamish-Munro Hall	315	> 6 *	Modern	No
Beamish-Munro Hall	326	8.7	Calculated	No
Biosciences Complex	1101	18.5	Measured	No
Biosciences Complex	1102	17.6	Measured	No
Biosciences Complex	1341	> 6 *	Modern	No
Biosciences Complex	2306	> 6 *	Modern	No
Biosciences Complex	2311	6.8	Calculated	No
Biosciences Complex	2312	> 6 *	Modern	No
Biosciences Complex	2319	> 6 *	Modern	No
Biosciences Complex	2320	> 6 *	Modern	No
Biosciences Complex	2325	> 6 *	Modern	No
Biosciences Complex	2326	> 6 *	Modern	No
Biosciences Complex	3110	> 6 *	Modern	No
Biosciences Complex	3112	> 6 *	Modern	No
Biosciences Complex	3306	> 6 *	Modern	No
Biosciences Complex	3311	> 6 *	Modern	No
Biosciences Complex	3312	> 6 *	Modern	No
Biosciences Complex	3319	> 6 *	Modern	No
Biosciences Complex	3320	> 6 *	Modern	No
Biosciences Complex	3326	> 6 *	Modern	No
Botterell Hall	351	12.5	Measured	No
Botterell Hall	449	9.5	Calculated	No
Botterell Hall	568	11.2	Calculated	No
Botterell Hall	569A	7.6	Measured	Yes
Botterell Hall	816	16.3	Calculated	No
Botterell Hall	942	6.9	Calculated	No
Botterell Hall	B129	5.2	Calculated	No
Botterell Hall	B139	5.5	Measured	No
Botterell Hall	B143	5.2	Measured	Yes
Botterell Hall	B147	11.3	Measured	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Botterell Hall	B148	19.6	Calculated	No
Botterell Hall	B150	9.1	Calculated	No
Bruce Wing	138	7.7	Calculated	No
Bruce Wing	234B	7.2	Calculated	No
Bruce Wing	239	8.0	Calculated	No
Bruce Wing	329	7.0	Measured	Yes
Bruce Wing	352	5.1	Calculated	No
Bruce Wing	454	10.4	Calculated	No
Bruce Wing	456	8.6	Calculated	No
Carruthers Hall	102	7.5	Measured	No
Carruthers Hall	311	13.2	Calculated	No
Cataraqui Building	206	11.2	Measured	Yes
Cataraqui Building	206B	9.8	Measured	No
Cataraqui Building	207	17.2	Measured	Yes
Cataraqui Building	220	6.4	Measured	Yes
Cataraqui Building	221	10.7	Measured	Yes
Cataraqui Building	222	8.5	Measured	Yes
Chernoff Hall	117	5.4	Measured	No
Chernoff Hall	118	10.1	Measured	No
Chernoff Hall	120	> 6 *	Modern	No
Chernoff Hall	122	> 6 *	Modern	No
Chernoff Hall	202	> 6 *	Modern	No
Chernoff Hall	206	> 6 *	Modern	No
Chernoff Hall	210	7.0	Measured	No
Chernoff Hall	211	> 6 *	Modern	No
Chernoff Hall	213	> 6 *	Modern	No
Chernoff Hall	250	7.2	Measured	No
Chernoff Hall	415	> 6 *	Modern	No
Coastal Engineering Lab	106	8.1	Measured	Yes
Coastal Engineering Lab	202	11.3	Calculated	No
Duncan McArthur Hall	A207	7.3	Calculated	No
Duncan McArthur Hall	A211	7.2	Calculated	No
Duncan McArthur Hall	A219	7.3	Calculated	No
Duncan McArthur Hall	A227	6.6	Calculated	No
Duncan McArthur Hall	A229	10.1	Calculated	No
Duncan McArthur Hall	A232	10.1	Calculated	No
Duncan McArthur Hall	A234	7.9	Calculated	No
Duncan McArthur Hall	A236	9.4	Calculated	No
Duncan McArthur Hall	A237	10.1	Measured	No
Duncan McArthur Hall	A239	10.5	Calculated	No
Duncan McArthur Hall	A240	9.4	Calculated	No
Duncan McArthur Hall	A241	7.3	Calculated	No
Duncan McArthur Hall	A242	7.1	Calculated	No
Duncan McArthur Hall	A243	10.4	Calculated	No
Duncan McArthur Hall	A244	7.5	Calculated	No
Duncan McArthur Hall	A301	8.7	Calculated	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Duncan McArthur Hall	A313	14.4	Measured	Yes
Duncan McArthur Hall	A317	13.1	Measured	Yes
Duncan McArthur Hall	A321	8.6	Calculated	No
Duncan McArthur Hall	A325	18.9	Measured	Yes
Duncan McArthur Hall	A330	17.0	Calculated	No
Duncan McArthur Hall	A330A	13.2	Calculated	No
Duncan McArthur Hall	A332	11.7	Calculated	No
Duncan McArthur Hall	A333	12.6	Calculated	No
Duncan McArthur Hall	A334	7.4	Calculated	No
Duncan McArthur Hall	A335	9.4	Calculated	No
Duncan McArthur Hall	A339	12.0	Calculated	No
Duncan McArthur Hall	A341	17.5	Calculated	No
Duncan McArthur Hall	A342A	10.6	Calculated	No
Duncan McArthur Hall	A342B	8.5	Calculated	No
Duncan McArthur Hall	A343	11.5	Calculated	No
Duncan McArthur Hall	B101	12.5	Calculated	No
Duncan McArthur Hall	B133	5.0	Calculated	No
Duncan McArthur Hall	B142	6.8	Calculated	No
Duncan McArthur Hall	B151	9.7	Calculated	No
Duncan McArthur Hall	B151A	17.6	Calculated	No
Duncan McArthur Hall	B157	7.7	Calculated	No
Duncan McArthur Hall	B157B	16.9	Calculated	No
Duncan McArthur Hall	B180	11.1	Calculated	No
Duncan McArthur Hall	B204	10.1	Calculated	No
Duncan McArthur Hall	B219	9.7	Calculated	No
Duncan McArthur Hall	B219B	9.9	Calculated	No
Duncan McArthur Hall	B219C	10.8	Calculated	No
Duncan McArthur Hall	B219D	10.9	Calculated	No
Duncan McArthur Hall	B230	15.6	Calculated	No
Duncan McArthur Hall	B245B	8.6	Calculated	No
Duncan McArthur Hall	B307	8.1	Calculated	No
Dunning Hall	010	9.9	Calculated	No
Dunning Hall	011	5.6	Measured	Yes
Dunning Hall	012	5.0	Measured	No
Dunning Hall	014	8.0	Measured	No
Dunning Hall	020	10.3	Measured	No
Dunning Hall	027	8.4	Calculated	No
Dunning Hall	213	6.3	Calculated	No
Dupuis Hall	215	8.5	Measured	No
Dupuis Hall	217	9.7	Measured	No
Dupuis Hall	236	9.0	Calculated	No
Dupuis Hall	242	34.9	Measured	No
Dupuis Hall	311	7.2	Calculated	No
Dupuis Hall	B09	6.1	Calculated	No
Dupuis Hall	B20	16.3	Calculated	No
Dupuis Hall	B22	6.8	Calculated	No

<i>Building Name</i>	<i>Room Code</i>	<i>eACH</i>	<i>Source</i>	<i>HEPA Filter(s)</i>
Dupuis Hall	B29	13.3	Calculated	No
Dupuis Hall	G01	13.7	Measured	No
Ellis Hall	008B	10.0	Calculated	No
Ellis Hall	026	5.4	Measured	Yes
Ellis Hall	038	7.8	Calculated	No
Ellis Hall	043	19.1	Calculated	No
Ellis Hall	052	7.2	Measured	Yes
Ellis Hall	126	7.1	Calculated	No
Ellis Hall	152	8.2	Measured	No
Ellis Hall	218	9.0	Calculated	No
Ellis Hall	226	9.6	Calculated	No
Ellis Hall	232	11.6	Calculated	No
Ellis Hall	319	12.8	Calculated	No
Ellis Hall	321	5.9	Measured	No
Ellis Hall	324	7.6	Measured	No
Ellis Hall	333	12.7	Calculated	No
Etherington Hall	1031	17.2	Measured	No
Faculty of Law -128 Union St.	001	8.6	Measured	No
Faculty of Law -128 Union St.	002	8.7	Calculated	No
Faculty of Law -128 Union St.	003	14.6	Calculated	No
Faculty of Law -128 Union St.	004	8.8	Calculated	No
Faculty of Law -128 Union St.	201	10.5	Measured	No
Faculty of Law -128 Union St.	202	16.6	Calculated	No
Faculty of Law -128 Union St.	211	19.3	Calculated	No
Faculty of Law -128 Union St.	300	11.2	Calculated	No
Faculty of Law -128 Union St.	400	11.9	Calculated	No
Faculty of Law -128 Union St.	515	6.4	Calculated	No
Faculty of Law -128 Union St.	001	8.6	Measured	No
Faculty of Law -128 Union St.	212	5.6	Measured	Yes
Faculty of Law -128 Union St.	213	7.5	Measured	No
Faculty of Law -128 Union St.	214	10.2	Measured	No
Faculty of Law -128 Union St.	214E	8.1	Measured	No
Faculty of Law -128 Union St.	214F	8.7	Measured	No
Faculty of Law -128 Union St.	214G	8.3	Measured	No
Fleming Hall Jemmett Wing	410	6.9	Calculated	No
Goodes Hall	100	> 6 *	Modern	No
Goodes Hall	101	> 6 *	Modern	No
Goodes Hall	102	> 6 *	Modern	No
Goodes Hall	103	> 6 *	Modern	No
Goodes Hall	108	8.3	Measured	No
Goodes Hall	118	8.7	Measured	No
Goodes Hall	120	> 6 *	Modern	No
Goodes Hall	141	9.5	Measured	No
Goodes Hall	151	9.1	Measured	No
Goodes Hall	153	9.0	Measured	No
Goodes Hall	300	> 6 *	Modern	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Goodes Hall	301A	> 6 *	Modern	No
Goodes Hall	302	> 6 *	Modern	No
Goodes Hall	303	> 6 *	Modern	No
Goodes Hall	304	> 6 *	Modern	No
Goodes Hall	305	> 6 *	Modern	No
Goodes Hall	308	> 6 *	Modern	No
Goodes Hall	312	> 6 *	Modern	No
Goodes Hall	LL200	> 6 *	Modern	No
Goodes Hall	LL200A	> 6 *	Modern	No
Goodwin Hall	120	6.3	Calculated	No
Goodwin Hall	120D	5.1	Measured	Yes
Goodwin Hall	132	14.8	Calculated	No
Goodwin Hall	221	11.0	Calculated	No
Goodwin Hall	230	9.4	Calculated	No
Goodwin Hall	241	5.9	Calculated	No
Goodwin Hall	247	6.2	Calculated	No
Goodwin Hall	248	6.1	Calculated	No
Goodwin Hall	254	6.2	Calculated	No
Goodwin Hall	330	10.3	Calculated	No
Goodwin Hall	438	7.3	Calculated	No
Goodwin Hall	443	8.2	Calculated	No
Goodwin Hall	449	7.9	Calculated	No
Goodwin Hall	521	8.8	Calculated	No
Harrison-LeCaine Hall	101	16.9	Calculated	No
Harrison-LeCaine Hall	102	9.7	Calculated	No
Harrison-LeCaine Hall	103	17.3	Calculated	No
Harrison-LeCaine Hall	104	10.2	Calculated	No
Harrison-LeCaine Hall	105	17.3	Calculated	No
Harrison-LeCaine Hall	106	10.2	Calculated	No
Harrison-LeCaine Hall	107	17.3	Calculated	No
Harrison-LeCaine Hall	108	10.2	Calculated	No
Harrison-LeCaine Hall	109	17.3	Calculated	No
Harrison-LeCaine Hall	110	10.2	Calculated	No
Harrison-LeCaine Hall	111	17.3	Calculated	No
Harrison-LeCaine Hall	112	10.2	Calculated	No
Harrison-LeCaine Hall	114	10.2	Calculated	No
Harrison-LeCaine Hall	115	5.3	Calculated	No
Harrison-LeCaine Hall	115A	16.0	Calculated	No
Harrison-LeCaine Hall	120	12.4	Calculated	No
Harrison-LeCaine Hall	124	13.4	Calculated	No
Harrison-LeCaine Hall	125	6.4	Calculated	No
Harrison-LeCaine Hall	126	6.6	Calculated	No
Harrison-LeCaine Hall	127	15.1	Calculated	No
Harrison-LeCaine Hall	127A	8.2	Calculated	No
Harrison-LeCaine Hall	128	7.1	Calculated	No
Harrison-LeCaine Hall	213	10.2	Calculated	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Harrison-LeCaine Hall	214	12.7	Calculated	No
Harrison-LeCaine Hall	220	7.7	Calculated	No
Harrison-LeCaine Hall	223	7.7	Calculated	No
Harrison-LeCaine Hall	225	7.7	Calculated	No
Harrison-LeCaine Hall	227	15.9	Calculated	No
Harrison-LeCaine Hall	228	8.2	Calculated	No
Harrison-LeCaine Hall	229	8.5	Calculated	No
Harrison-LeCaine Hall	304	9.9	Calculated	No
Harrison-LeCaine Hall	303	8.6	Calculated	No
Harrison-LeCaine Hall	307	8.6	Calculated	No
Harrison-LeCaine Hall	308	10.1	Calculated	No
Harrison-LeCaine Hall	311	8.6	Calculated	No
Harrison-LeCaine Hall	312	9.3	Calculated	No
Harrison-LeCaine Hall	315	8.5	Calculated	No
Harrison-LeCaine Hall	316	9.9	Calculated	No
Humphrey Hall	102	10.2	Measured	No
Humphrey Hall	131	11.0	Calculated	No
Humphrey Hall	132	10.6	Calculated	No
Humphrey Hall	219	16.9	Calculated	No
Humphrey Hall	223	8.2	Calculated	No
Isabel Bader Centre	104	> 6 *	Modern	No
Isabel Bader Centre	105	> 6 *	Modern	No
Isabel Bader Centre	118	> 6 *	Modern	No
Isabel Bader Centre	122	13.2	Measured	No
Isabel Bader Centre	126A	> 6 *	Modern	No
Isabel Bader Centre	126B	> 6 *	Modern	No
Isabel Bader Centre	126C	> 6 *	Modern	No
Isabel Bader Centre	126D	> 6 *	Modern	No
Isabel Bader Centre	128	> 6 *	Modern	No
Isabel Bader Centre	307	> 6 *	Modern	No
Isabel Bader Centre	312	> 6 *	Modern	No
Isabel Bader Centre	313A	> 6 *	Modern	No
Isabel Bader Centre	322	> 6 *	Modern	No
Isabel Bader Centre	323	> 6 *	Modern	No
Isabel Bader Centre	324	> 6 *	Modern	No
Isabel Bader Centre	325	> 6 *	Modern	No
Isabel Bader Centre	326	> 6 *	Modern	No
Isabel Bader Centre	327	> 6 *	Modern	No
Isabel Bader Centre	328	> 6 *	Modern	No
Isabel Bader Centre	329	> 6 *	Modern	No
Isabel Bader Centre	336	> 6 *	Modern	No
Isabel Bader Centre	342	> 6 *	Modern	No
Jackson Hall	116	6.3	Measured	Yes
Jackson Hall	302	5.9	Measured	Yes
Jackson Hall	303	5.6	Measured	Yes
Jeffery Hall	101	5.7	Measured	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Jeffery Hall	102	8.5	Measured	No
Jeffery Hall	110	5.9	Measured	No
Jeffery Hall	115	7.0	Measured	No
Jeffery Hall	116	6.5	Measured	No
Jeffery Hall	118	5.5	Measured	No
Jeffery Hall	125	9.5	Calculated	No
Jeffery Hall	126	5.5	Measured	No
Jeffery Hall	127	5.2	Measured	No
Jeffery Hall	128	6.7	Measured	Yes
Jeffery Hall	155	5.5	Measured	No
Jeffery Hall	157	6.1	Measured	No
Jeffery Hall	222	5.6	Measured	No
Jeffery Hall	225	11.4	Measured	No
Jeffery Hall	234	10.1	Measured	No
Jeffery Hall	319	13.7	Measured	No
Jeffery Hall	422	17.8	Measured	No
Kinesiology and Health Building	100	6.8	Measured	No
Kinesiology and Health Building	101	10.1	Measured	No
Kinesiology and Health Building	102	> 6 *	Modern	No
Kinesiology and Health Building	103	> 6 *	Modern	No
Kinesiology and Health Building	104	> 6 *	Modern	No
Kinesiology and Health Building	105	> 6 *	Modern	No
Kinesiology and Health Building	106	> 6 *	Modern	No
Kinesiology and Health Building	107	> 6 *	Modern	No
Kinesiology and Health Building	202	> 6 *	Modern	No
Kinesiology and Health Building	203	> 6 *	Modern	No
Kinesiology and Health Building	212	> 6 *	Modern	No
Kingston Hall	100	6.8	Measured	Yes
Kingston Hall	101	13.5	Measured	No
Kingston Hall	104	9.4	Measured	Yes
Kingston Hall	108	7.9	Measured	Yes
Kingston Hall	112	5.8	Measured	Yes
Kingston Hall	200	6.8	Measured	No
Kingston Hall	201	8.0	Measured	No
Kingston Hall	202	5.3	Measured	Yes
Kingston Hall	204	7.1	Measured	Yes
Kingston Hall	205	6.8	Measured	Yes
Kingston Hall	208	8.8	Measured	Yes
Kingston Hall	209	17.3	Measured	Yes
Kingston Hall	210	17.3	Measured	Yes
Kingston Hall	302	6.7	Calculated	No
Kingston Hall	304	5.0	Measured	Yes
Kingston Hall	308	5.4	Measured	Yes
Kingston Hall	313	6.7	Measured	Yes
Louise D. Acton	107	11.4	Calculated	No
Louise D. Acton	110	11.4	Calculated	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Louise D. Acton	111A	6.7	Calculated	No
Louise D. Acton	111B	6.0	Calculated	No
Louise D. Acton	112	5.7	Calculated	No
Louise D. Acton	113	6.6	Calculated	No
Louise D. Acton	114	6.6	Calculated	No
Louise D. Acton	115	6.7	Calculated	No
Louise D. Acton	116	6.6	Calculated	No
Louise D. Acton	117	6.7	Calculated	No
Louise D. Acton	119	7.0	Calculated	No
Louise D. Acton	12-008	5.7	Measured	Yes
Louise D. Acton	12-021	5.3	Measured	Yes
Louise D. Acton	12-026	13.5	Measured	Yes
Louise D. Acton	13-119	5.6	Calculated	No
Louise D. Acton	122A	6.9	Calculated	No
Louise D. Acton	122B	6.9	Calculated	No
Louise D. Acton	204CL	7.9	Calculated	No
Louise D. Acton	205CL	11.2	Calculated	No
Louise D. Acton	206CL	11.2	Calculated	No
Louise D. Acton	207CL	6.0	Calculated	No
Louise D. Acton	211CL	6.7	Calculated	No
Louise D. Acton	212CL	6.1	Calculated	No
Louise D. Acton	213CL	6.1	Calculated	No
Louise D. Acton	214CL	6.6	Calculated	No
Louise D. Acton	215CL	6.6	Calculated	No
Louise D. Acton	216CL	6.8	Calculated	No
Louise D. Acton	217ACL	6.8	Calculated	No
Louise D. Acton	217BCL	6.7	Calculated	No
Louise D. Acton	224CL	5.9	Calculated	No
Louise D. Acton	227CL	9.0	Calculated	No
Louise D. Acton	228CL	9.2	Calculated	No
MacIntosh-Corry Hall	A309	6.0	Calculated	No
MacIntosh-Corry Hall	A311	6.0	Calculated	No
MacIntosh-Corry Hall	A416	8.9	Calculated	No
MacIntosh-Corry Hall	A516	8.9	Calculated	No
MacIntosh-Corry Hall	B139A	19.8	Calculated	No
MacIntosh-Corry Hall	B201	6.0	Calculated	No
MacIntosh-Corry Hall	B313	7.3	Calculated	No
MacIntosh-Corry Hall	C416	8.3	Calculated	No
MacIntosh-Corry Hall	C420	8.2	Calculated	No
MacIntosh-Corry Hall	C508	5.6	Calculated	No
MacIntosh-Corry Hall	D122	5.4	Calculated	No
MacIntosh-Corry Hall	D201	14.2	Measured	No
MacIntosh-Corry Hall	D214	9.6	Measured	Yes
MacIntosh-Corry Hall	D216	11.4	Measured	Yes
MacIntosh-Corry Hall	D326	7.9	Calculated	No
MacIntosh-Corry Hall	D405	7.8	Calculated	No



<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
MacIntosh-Corry Hall	D432	10.7	Calculated	No
MacIntosh-Corry Hall	E104	6.3	Calculated	No
MacIntosh-Corry Hall	E202	7.8	Calculated	No
MacIntosh-Corry Hall	E223	13.3	Calculated	No
MacIntosh-Corry Hall	E229	7.0	Calculated	No
MacIntosh-Corry Hall	E230	6.8	Calculated	No
MacIntosh-Corry Hall	E314	8.2	Calculated	No
McLaughlan Hall	103	> 6 *	Modern	No
McLaughlan Hall	109	11.7	Calculated	No
McLaughlan Hall	110	6.2	Measured	Yes
McLaughlan Hall	110B	> 6 *	Modern	No
McLaughlan Hall	110D	> 6 *	Modern	No
McLaughlan Hall	114	6.2	Measured	Yes
McLaughlan Hall	306	5.9	Calculated	No
McLaughlan Hall	315	7.4	Measured	No
Miller Hall	100A	7.6	Measured	Yes
Miller Hall	102	5.1	Measured	Yes
Miller Hall	105	7.8	Measured	No
Miller Hall	106	6.6	Measured	Yes
Miller Hall	201	6.4	Measured	Yes
Miller Hall	205	5.1	Calculated	Yes
Miller Hall	210	9.9	Measured	Yes
Miller Hall	215	13.8	Calculated	Yes
Miller Hall	225	5.5	Measured	Yes
Miller Hall	319	8.8	Measured	Yes
Miller Hall	322	6.1	Measured	Yes
Miller Hall	329	9.3	Measured	Yes
Miller Hall	407	5.9	Measured	Yes
Miller Hall	409	5.5	Measured	Yes
Miller Hall	B02A	9.5	Calculated	Yes
Miller Hall	B10	12.5	Calculated	Yes
Mitchell Hall	126	> 6 *	Modern	No
Mitchell Hall	130	> 6 *	Modern	No
Mitchell Hall	211	> 6 *	Modern	No
Mitchell Hall	211A	> 6 *	Modern	No
Mitchell Hall	215	8.2	Measured	No
Mitchell Hall	225	7.7	Measured	No
Mitchell Hall	235	8.8	Measured	No
Nicol Hall	107	11.3	Measured	Yes
Nicol Hall	201	6.7	Measured	Yes
Nicol Hall	203	15.8	Measured	No
Nicol Hall	204	16.3	Measured	Yes
Nicol Hall	205	8.6	Measured	Yes
Nicol Hall	232	6.6	Measured	No
Nicol Hall	321	5.4	Measured	No
Ontario Hall	106	7.2	Measured	Yes

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Ontario Hall	107	6.6	Measured	Yes
Ontario Hall	108	5.6	Measured	Yes
Ontario Hall	109	6.4	Measured	Yes
Ontario Hall	111	12.1	Measured	Yes
Ontario Hall	113	18.1	Measured	No
Ontario Hall	114	5.7	Measured	Yes
Ontario Hall	115	10.3	Measured	Yes
Ontario Hall	206	12.0	Measured	Yes
Ontario Hall	207	5.9	Measured	Yes
Ontario Hall	208	6.4	Measured	No
Ontario Hall	209	7.7	Measured	Yes
Ontario Hall	210	10.8	Measured	Yes
Ontario Hall	214	12.9	Measured	Yes
Ontario Hall	215	6.4	Measured	Yes
Ontario Hall	216	6.8	Measured	Yes
Ontario Hall	221	7.6	Measured	Yes
Ontario Hall	221B	31.9	Measured	Yes
Ontario Hall	222	17.2	Measured	Yes
Ontario Hall	223	5.3	Measured	No
Ontario Hall	307	6.8	Measured	Yes
Ontario Hall	308	9.4	Measured	Yes
Ontario Hall	309	5.8	Measured	Yes
Ontario Hall	405	6.7	Measured	Yes
Ontario Hall	408	8.8	Measured	No
Ontario Hall	410	8.1	Measured	No
Richardson Labs	101	14.1	Measured	Yes
Richardson Labs	102	8.1	Calculated	No
Richardson Labs	104	19.4	Measured	No
Richardson Labs	107	6.1	Calculated	No
School of Medicine	021	> 6 *	Modern	No
School of Medicine	032A	21.5	Measured	No
School of Medicine	101A	> 6 *	Modern	No
School of Medicine	101B	> 6 *	Modern	No
School of Medicine	101C	> 6 *	Modern	No
School of Medicine	101D	> 6 *	Modern	No
School of Medicine	101E	> 6 *	Modern	No
School of Medicine	101F	> 6 *	Modern	No
School of Medicine	101G	> 6 *	Modern	No
School of Medicine	101H	> 6 *	Modern	No
School of Medicine	101J	> 6 *	Modern	No
School of Medicine	101K	> 6 *	Modern	No
School of Medicine	101L	> 6 *	Modern	No
School of Medicine	101M	> 6 *	Modern	No
School of Medicine	101N	> 6 *	Modern	No
School of Medicine	101P	> 6 *	Modern	No
School of Medicine	101Q	> 6 *	Modern	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
School of Medicine	101R	> 6 *	Modern	No
School of Medicine	101S	> 6 *	Modern	No
School of Medicine	101T	> 6 *	Modern	No
School of Medicine	101U	> 6 *	Modern	No
School of Medicine	101V	> 6 *	Modern	No
School of Medicine	112	> 6 *	Modern	No
School of Medicine	114	> 6 *	Modern	No
School of Medicine	132A	20.8	Measured	No
School of Medicine	200	> 6 *	Modern	No
School of Medicine	202	> 6 *	Modern	No
School of Medicine	203A	> 6 *	Modern	No
School of Medicine	203B	> 6 *	Modern	No
School of Medicine	203C	> 6 *	Modern	No
School of Medicine	206A	> 6 *	Modern	No
School of Medicine	206C	> 6 *	Modern	No
School of Medicine	234A	> 6 *	Modern	No
School of Medicine	234B	> 6 *	Modern	No
School of Medicine	234C	> 6 *	Modern	No
School of Medicine	234D	> 6 *	Modern	No
School of Medicine	234E	> 6 *	Modern	No
School of Medicine	234F	> 6 *	Modern	No
School of Medicine	302A	> 6 *	Modern	No
School of Medicine	302B	12.9	Measured	No
School of Medicine	322A	> 6 *	Modern	No
School of Medicine	323	> 6 *	Modern	No
School of Medicine	400A	> 6 *	Modern	No
School of Medicine	400B	12.4	Measured	No
School of Medicine	400C	> 6 *	Modern	No
School of Medicine	401A	5.3	Measured	No
School of Medicine	401B	> 6 *	Modern	No
Stirling Hall	301A	11.2	Measured	No
Stirling Hall	301B	14.1	Measured	No
Stirling Hall	301C	13.5	Measured	No
Stirling Hall	301D	7.6	Measured	No
Stirling Hall	401	9.4	Calculated	No
Stirling Hall	402	7.3	Measured	No
Stirling Hall	403	5.1	Measured	No
Stirling Hall	404	10.2	Measured	No
Stirling Hall	404A	12.7	Calculated	No
Stirling Hall	405	15.1	Measured	No
Stirling Hall	406	9.4	Calculated	No
Stirling Hall	407	9.4	Calculated	No
Stirling Hall	409	10.5	Measured	No
Stirling Hall	410	10.5	Measured	No
Stirling Hall	412A	9.4	Calculated	No
Stirling Hall	414	5.0	Measured	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Stirling Hall	503	9.4	Measured	No
Stirling Hall	504	5.6	Measured	No
Stirling Hall	504A	6.1	Calculated	No
Stirling Hall	504B	9.3	Calculated	No
Stirling Hall	504C	27.8	Calculated	No
Stirling Hall	505	22.3	Calculated	No
Stirling Hall	505A	6.7	Measured	Yes
Stirling Hall	506	12.8	Measured	No
Stirling Hall	506A	22.0	Calculated	No
Stirling Hall	506B	8.6	Calculated	No
Stirling Hall	506C	9.0	Calculated	No
Stirling Hall	506D	8.6	Calculated	No
Stirling Hall	506E	7.8	Calculated	No
Stirling Hall	507	8.7	Measured	No
Stirling Hall	507A	6.2	Calculated	No
Stirling Hall	507B	10.3	Calculated	No
Stirling Hall	508	9.1	Measured	No
Stirling Hall	508A	6.8	Calculated	No
Stirling Hall	508B	12.3	Calculated	No
Stirling Hall	508C	9.3	Calculated	No
Stirling Hall	508D	11.1	Calculated	No
Stirling Hall	509	13.0	Measured	No
Stirling Hall	512	5.9	Measured	No
Stirling Hall	513	5.8	Measured	No
Stirling Hall	514	6.0	Measured	No
Sutherland Hall	145	12.4	Calculated	No
Sutherland Hall	202	11.8	Calculated	No
Sutherland Hall	212	12.5	Calculated	No
Sutherland Hall	305	13.3	Calculated	No
Sutherland Hall	334	20.3	Calculated	No
Sutherland Hall	554	18.3	Calculated	No
Theological Hall	001	> 6 *	Modern	No
Theological Hall	027	15.8	Measured	Yes
Theological Hall	101	14.7	Calculated	No
Theological Hall	102	8.1	Measured	Yes
Theological Hall	106	6.7	Calculated	No
Theological Hall	115	9.1	Calculated	No
Theological Hall	118	8.3	Measured	Yes
Theological Hall	203	5.3	Calculated	No
Theological Hall	209	6.0	Calculated	No
Theological Hall	215	15.2	Measured	Yes
Theological Hall	216	17.7	Calculated	No
Theological Hall	226	11.7	Measured	Yes
Theological Hall	302	> 6 *	Modern	No
Theological Hall	415	18.4	Calculated	No
Walter Light Hall	205	8.3	Measured	No

<b>Building Name</b>	<b>Room Code</b>	<b>eACH</b>	<b>Source</b>	<b>HEPA Filter(s)</b>
Walter Light Hall	210	10.1	Measured	No
Walter Light Hall	212	9.7	Calculated	No
Walter Light Hall	214	7.4	Measured	Yes
Walter Light Hall	310	7.4	Calculated	No
Walter Light Hall	620	5.5	Measured	Yes
Walter Light Hall	722	5.4	Measured	Yes
Watson Hall	114	15.7	Calculated	No
Watson Hall	122	6.7	Calculated	No
Watson Hall	207	17.7	Measured	Yes
Watson Hall	217	15.0	Calculated	No
Watson Hall	401	8.9	Measured	Yes
Watson Hall	411	6.8	Measured	Yes
Watson Hall	522	9.2	Calculated	No

\* These are modern systems. Spot checks have been conducted to verify they are exceeding 6 eACH.