

# ENERGY MANAGEMENT AT QUEEN'S



## Queen's University – Electricity Demand Management

Physical Plant Services will publish a forecast for Demand Management weekly when no reduction signals are present. If extreme weather and high provincial demand is present notification will be sent twice a week.

For more information please visit:

<http://www.queensu.ca/sustainability/campus-initiatives/energy/demand-management>

### Protocol for Security - (613) 533 6080 internal (36080)

If security receives phone calls regarding A/C issues in the affected buildings during hours highlighted below in red, there is no need to call a controls mechanic as they will be coordinating the shutdown. Please allow an additional 30–45 minutes after the shutdown hours for systems to restart and recover after the end of the response period.

No Reduction Expected

Potential Demand Response Day

Confirmed Demand Response Day

#### Affected Buildings:

##### Chiller to remain running with reduced load:

- ⇒ Biosciences Complex - Atrium and Lecture Theatres
- ⇒ Chernoff Hall - Administration Wing & Theatres
- ⇒ Douglas Library - Except Special Collections

##### Chiller to remain off for expected response duration:

Dunning Hall, Gordon Hall, Jeffery Hall, Macdonald Hall, Richardson Hall, Rideau Building, Stauffer Library and Watson Hall

##### Exceptions:

- ⇒ Queen's Centre and School of Kinesiology (4 PM - 6 PM only)

##### Full Exemptions - no response:

Beamish-Munro Hall

Date	Expected Response Hours
Aug 14, 2017	n/a
Aug 15, 2017	3:00—9:00
Aug 16, 2017	3:00—9:00
Aug 17, 2017	3:00—9:00
Aug 18, 2017	n/a

**Publication Date**  
**August 14, 2017**

**Questions? Contact Fixit:**

ext. 77301 or [fixit@queensu.ca](mailto:fixit@queensu.ca)