

ENERGY MANAGEMENT AT QUEEN'S



Queen's University – Electricity Demand Management

Physical Plant Services will publish a forecast for Demand Management weekly when no reduction signals are present. If extreme weather and high provincial demand is present notification will be sent twice a week.

For more information please visit:

<http://www.queensu.ca/sustainability/campus-initiatives/energy/demand-management>

Protocol for Security - (613) 533 6080 internal (36080)

If security receives phone calls regarding A/C issues in the affected buildings during hours highlighted below in red, there is no need to call a controls mechanic as they will be coordinating the shutdown. Please allow an additional 30–45 minutes after the shutdown hours for systems to restart and recover after the end of the response period.

No Reduction Expected

Potential Demand Response Day

Confirmed Demand Response Day

Affected Buildings:

Chiller to remain running with reduced load:

- ⇒ Douglas Library - Except Special Collections
- ⇒ Chernoff Hall - Admin Wing and Lecture Theatres
- ⇒ Biosciences Complex—Atrium and Lecture Theatres

Chiller to remain off for expected response duration:

Dunning Hall, Gordon Hall, Jeffery Hall, Macdonald Hall, Richardson Hall, Rideau Building, Stauffer Library and Watson Hall

Exceptions:

- ⇒ Queen's Centre and School of Kinesiology (12 - 2 PM only)

Please Note: Dependent on weather conditions in Toronto chillers may be able to return online earlier than expected.

Date	Expected Response Hours
June 18, 2018	12:00-4:00
June 19, 2018	n/a
June 20, 2018	n/a
June 21, 2018	n/a
June 22, 2018	n/a

Publication Date
June 18, 2018

Questions? Contact Fixit:

ext. 77301 or fixit@queensu.ca