

# ENERGY MANAGEMENT AT QUEEN'S



## Queen's University – Electricity Demand Management

Physical Plant Services will publish a forecast for Demand Management weekly when no reduction signals are present. If extreme weather and high provincial demand is present notification will be sent twice a week.

For more information please visit:

<http://www.queensu.ca/sustainability/campus-initiatives/energy/demand-management>

## Protocol for Security - (613) 533 6080 internal (36080)

If security receives phone calls regarding A/C issues in the affected buildings during hours highlighted below in red, there is no need to call a controls mechanic as they will be coordinating the shutdown. Please allow an additional 30–45 minutes after the shutdown hours for systems to restart and recover after the end of the response period.

No Reduction Expected

Potential Demand Response Day

Confirmed Demand Response Day

### Affected Buildings:

Chiller to remain off for expected response duration:

Rideau Building

### Exceptions:

⇒ Queen's Centre and  
School of Kinesiology (5 PM - 7 PM only)

### Full Exemptions - no response:

Beamish-Munro Hall, Biosciences Complex,  
Chernoff Hall, Douglas Library, Dunning Hall,  
Gordon Hall, Jeffery Hall, Macdonald Hall,  
Stauffer Library and Watson Hall

Date	Expected Response Hours
Sept 25, 2017	3:00—9:00
Sept 26, 2017	3:00—9:00
Sept 27, 2017	3:00—9:00
Sept 28, 2017	n/a
Sept 29, 2017	n/a

**Publication Date**  
**September 25, 2017**

**Questions? Contact Fixit:**

ext. 77301 or [fixit@queensu.ca](mailto:fixit@queensu.ca)