

ENERGY MANAGEMENT

@ QUEEN'S



Queen's University – Electricity Demand Management

Physical Plant Services will publish a forecast for Demand Management weekly when no reduction signals are present. If extreme weather and high Provincial Demand is present Notification will be sent twice a week.

For more information please see visit:

<http://www.queensu.ca/sustainability/campus-initiatives/energy/demand-management>

Protocol for Security - (613) 533 6080 internal (36080)

If Security receives phone calls regarding A/C issues in the affected buildings during hours highlighted below in RED, there is no need to call a controls mechanic as they will be coordinating the shutdown. Please allow an additional 30– 45 minutes after the shutdown hours for systems to restart and recover after the end of the response period.

No Reduction Expected Potential

Demand Response Day Confirmed

Demand Response Day

Affected Buildings:

Chiller to remain running with reduced load:

BioSciences - Atrium and Lecture Theatres

Chernoff Hall - Administration Wing & Theatres (2 PM - 5:30 PM only)

Douglas Library - Except Special Collections

Chiller to remain off for expected response duration:

Beamish-Munro Hall, Gordon Hall, Jeffery Hall, John Deutsch University Centre (north retail space), Richardson Hall, Rideau Building, Stauffer Library, Stirling Hall and Watson Hall

Exceptions:

Dunning Hall (2 PM - 5 PM only)

Macdonald Hall (2 PM - 5:30 PM only)

Queen's Centre / School of Kinesiology (4 PM - 6 PM only)

Date	Expected Response Hours
06-Jul-15	2:00 PM - 8:00 PM
07-Jul-15	2:00 PM - 8:00 PM
08-Jul-15	n/a
09-Jul-15	n/a
10-Jul-15	n/a
11-Jul-15	n/a
12-Jul-15	n/a

Days 1 - 7 are based on IESO 7 Day Peak Forecast.

July 6, 2015

Contact Us:

Nathan Splinter 533 2961, splinter@queensu.ca
Fixit Desk : ext 77301, fixit@queensu.ca