

Spaces that were assessed and deemed not to be Confined Spaces

Building	Room	Description
Abramsky Hall	14	Pit Below Lift
Ban Righ	72	Storm Sump Pit
Biosciences Complex	4285	Cooling Tower North
Biosciences Complex	5th Floor Greenhouse	Cooling Tower South
Bruce Wing	154A	Walkin Fridge
Craine Building	Filter Rm Crawlspace	Crawl Space
Douglas Library	188	Condensate Pit
Douglas Library	188	Steam Tunnel
Dunning Hall	246	Pipe Chase Adjacent to Washrooms
Elec & Comm Pull Pits and Cover Plates	Ext/Outdoors Campuswide	Elec Pull Pits and Cover Plates
Jackson Hall	97	Condensate Pit
Jean Royce 1	Crawl Space	Crawl Space/Pipe Chase
Jeffery Hall	155	Crawl Space Under Raised Floor for IT Cables
Jeffery Hall	156	Crawl Space Under Raised Floor for IT Cables
KCVI - 235 Frontenac St	301	Roof Access Stairwell/Ceiling Crawlspace
Mitchell Hall	LL127D	Condensate Tank/Pit
New Medical	Ext/Outdoors	Vent Space for Future Elec Substation
Ontario Hall	405	Attic Spaces on 4th Floor
Queen's Centre / ARC	Pool Pit Space	Pool Pit
Refridgeration Plant		Cooling Tower
Richardson Stadium	P216	Crawl Space
Victoria Hall	D Wing Hallway	Hatch into Pipechase